

UE Declaration of Conformity

issued under the sole responsibility of the manufacturer

The object of this declaration is pressure device **APC-2000ALW in MID version.**

Manufacturer: **APLISENS S.A.,
ul. Morelowa 7, 03-192 Warszawa**

We hereby declare under the sole responsibility, that the object of the declaration defined above comply with relevant Union harmonization legislation.

Pressure transmitters type **APC-2000ALW** in MID version comply with directives/standards:

- **EMC – 2014/30/UE** dated 26 February 2014

Conformity assessment procedure: module A.

The following standard was applied EN 61326-1:2013, EN 12405-1:2005+A2:2010.

- **RoHS – 2011/65/UE** dated 08 June 2011

Conformity assessment procedure: module A, according to Decision No 768/2008/EC.

The following standard was applied EN 50581:2013-03.

- **ATEX – 2014/34/UE** dated 26 February 2014

Intrinsically safe versions of pressure transmitters are marked with the following certificate making:

II 1/2G Ex ia IIC T4/T5 Ga/Gb

FTZU 08 ATEX 0020X

Certificate (Module B) was issued by Notified Body no. 1026, Physical Technical Testing Institute, Pikartska 7, 716 07 Ostrava Radvanice.

The following standards were applied: EN 60079-0:2013-03+A11:2014-03, EN 60079-11:2012, EN 50303:2004.

Pressure transmitters APC-2000ALW in explosion-proof versions are marked with the following certificate marking:

II 1/2G Ex ia / db IIC T6/T5 Ga/Gb

KDB 08 ATEX 224X

Certificate (Module B) was issued by Notified Body no. 1453, Central Mining Institute, Plac Gwarków 1, 40-166 Katowice.

The following standards were applied: EN 60079-0:2013-03+A11:2014-03, EN 60079-1:2014-12, EN 60079-11:2012, EN 60079-26:2015-04, EN 60079-31:2014-10.

Notification of quality assurance is issued (Module D) by Notified Body no. 1453, Central Mining Institute, Plac Gwarków 1, 40-166 Katowice.

- **EN 12405-1:2005+A2:2010, Annex B, Pressure Transducers**

Harmonized to the **MID Directive: 2014/32/UE, MI-002**

Pressure transmitters APC-2000ALW in MID versions are marked with the above-named standard and parts certificate (Module B) no. 27/12 issued by Oil and Gas Institute – National Research Institute, Lubicz 25A, 31-503 Kraków.

Notification of quality assurance is issued (Module D) by Oil and Gas Institute – National Research Institute, Lubicz 25A, 31-503 Kraków.

Warsaw, 11.09.2018

Jan Wąsowski
Proxy of the Management Board

