



IECEx Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: **IECEx KDB 20.0001X** Page 1 of 5 [Certificate history:](#)

Status: **Current** Issue No: 0

Date of Issue: 2020-01-31

Applicant: **APLISENS S. A.**
ul. Morelowa 7
03-192 Warszawa
Poland

Equipment: **Smart rail mount temperature transmitters type LI-24L, LI-24L Safety; Smart head mount temperature transmitters type LI-24G, LI-24G Safety;**

Optional accessory:

Type of Protection: **Intrinsic safety "ia".**

Marking: Smart rail mount temperature transmitters type LI-24L, LI-24L Safety
Ex ia I Ma
Ex ia IIC T4/T5 Ga

Smart head mount temperature transmitters type LI-24G, LI-24G Safety
Ex ia I Ma
Ex ia IIC T5/T6 Ga
Ex ia IIIC T105°C Da

Approved for issue on behalf of the IECEx
Certification Body:

Andrzej Trębaczewski

Position:

Deputy Head of ExCB

Signature:
(for printed version)

Date:

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting www.iecex.com or use of this QR Code.



Certificate issued by:

Główny Instytut Górnictwa, Kopalnia Doświadczalna "BARBARA"
(Central Mining Institute Experimental Mine "Barbara")
ul. Podleska 72
43-190 Mikołów
Poland





IECEx Certificate of Conformity

Certificate No.: **IECEx KDB 20.0001X**

Page 2 of 5

Date of issue: 2020-01-31

Issue No: 0

Manufacturer: **APLISENS S. A.**
ul. Morelowa 7
03-192 Warszawa
Poland

Additional
manufacturing
locations:

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

IEC 60079-0:2017 Explosive atmospheres - Part 0: Equipment - General requirements
Edition:7.0

IEC 60079-11:2011 Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
Edition:6.0

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Report:

[PL/KDB/ExTR20.0001/00](#)

Quality Assessment Report:

[PL/KDB/QAR12.0001/04](#)



IECEx Certificate of Conformity

Certificate No.: **IECEx KDB 20.0001X**

Page 3 of 5

Date of issue: 2020-01-31

Issue No: 0

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

Smart temperature transmitters type LI-24L, LI-24L Safety, LI-24G, LI-24G Safety are designed to convert the signal from the sensor to a current signal 4...20mA, with Hart communication signal. Depending on the configuration, the transmitter is equipped with one or two measuring channels, enabling the measurement of difference, average, average with redundancy, minimum or maximum temperature. The transmitters enclosures are made of plastic.

SPECIFIC CONDITIONS OF USE: YES as shown below:

- The maximum temperature of the external heating source cannot heat the transmitter above the maximum ambient temperature declared by manufacturer.
- Temperature transmitters in potentially explosive areas should be installed in enclosures designed for operation in these areas and provide a minimum degree of protection: IP54 for Group I devices, IP20 for Group II devices and IP5X for Group III devices.
- In hazardous zones the transmitters should be installed in a way that prevents electrostatic charging, in accordance with the instructions.



IECEx Certificate of Conformity

Certificate No.: **IECEx KDB 20.0001X**

Page 4 of 5

Date of issue: 2020-01-31

Issue No: 0

Additional information:

Smart rail mount temperature transmitters type LI-24L, LI-24L Safety

Technical parameters:

Group I

Ambient temperature: -40°C+85°C (special version: -50°C)

Group II

Ambient temperature: -40°C+55°C (special version: -50°C)
Temperature class: T5

Ambient temperature: -40°C+85°C (special version: -50°C)
Temperature class: T4

Ingress protection of enclosure: IP20

Intrinsically safe parameters:

Supply from a power source with linear output characteristic (terminals +/-):

$U_i = 30V$ $L_i \sim 0$
 $I_i = 100mA$ $C_i = 2.5nF$
 $P_i = 0.75W$

Supply from a power source with rectangular output characteristic (terminals +/-):

I:

$U_i = 24V$ $L_i \sim 0$
 $I_i = 25mA$ $C_i = 2.5nF$
 $P_i = 0.6W$

II - only for $T_a = -40^\circ C + 85^\circ C$ (T4):

$U_i = 24V$ $L_i \sim 0$
 $I_i = 50mA$ $C_i = 2.5nF$
 $P_i = 1.2W$

Supply from a power source with trapezoidal output characteristic (terminals +/-):

$U_i = 24V$ $L_i \sim 0$
 $I_i = 50mA$ $C_i = 2.5nF$
 $P_i = 0.6W$

Output parameters (between any combination of terminals: 1...5):

$U_o = 6V$ $L_o = 2mH$
 $I_o = 3.3mA$ $C_o = 2.5\mu F$
 $P_o = 19.8mW$

Smart head mount temperature transmitters type LI-24G, LI-24G Safety



IECEx Certificate of Conformity

Certificate No.: **IECEx KDB 20.0001X**

Page 5 of 5

Date of issue: 2020-01-31

Issue No: 0

Technical parameters:

Group I

Ambient temperature: $-40^{\circ}\text{C}\div 70^{\circ}\text{C}$ (special version: -50°C)

Group II

Ambient temperature: $-40^{\circ}\text{C}\div 50^{\circ}\text{C}$ (special version: -50°C)
Temperature class: T6

Ambient temperature: $-40^{\circ}\text{C}\div 70^{\circ}\text{C}$ (special version: -50°C)
Temperature class: T5

Group III

Maximum surface temperature for dust atmospheres: 105°C

Ingress protection of enclosure: IP55

Ingress protection of terminals: IP10

Intrinsically safe parameters:

Supply from a power source with linear output characteristic (terminals +/-):

$U_i = 30\text{V}$ $L_i = 910\mu\text{H}$
 $I_i = 100\text{mA}$ $C_i = 2.5\text{nF}$
 $P_i = 0.75\text{W}$

Supply from a power source with rectangular output characteristic (terminals +/-):

$U_i = 24\text{V}$ $L_i = 910\mu\text{H}$
 $I_i = 25\text{mA}$ $C_i = 2.5\text{nF}$
 $P_i = 0.6\text{W}$

Supply from a power source with trapezoidal output characteristic (terminals +/-):

$U_i = 24\text{V}$ $L_i = 910\mu\text{H}$
 $I_i = 50\text{mA}$ $C_i = 2.5\text{nF}$
 $P_i = 0.6\text{W}$

Output parameters (between any combination of terminals: 1...5):

$U_o = 6\text{V}$ $L_o = 2\text{mH}$
 $I_o = 3.3\text{mA}$ $C_o = 2.5\mu\text{F}$
 $P_o = 19.8\text{mW}$