

## EC Declaration of Conformity

Document no. DZ.APT.ALW.Z4.ENG

Manufacturer: **APLISENS S.A.,  
ul. Morelowa 7, 03-192Warszawa**

We hereby acknowledge, that:

Smart temperature transmitters **APT-2000ALW** in all versions comply with directive

- **EMC – 2004/108/WE**

The following standard was applied PN-EN 61326-1:2009

Smart temperature transmitters **APT-2000ALW**  
in Exi and Exd version are comply with directive

- **ATEX – 94/9/WE**

Transmitters in Intrinsically Safe version are marked with the following certificate marking:

II 1/2G Ex ia IIC T4/T5/T6 Ga/Gb  
I M1 Ex ia I Ma (version with housing material ss316)  
II 1D Ex ia IIIC T105°C Da

Certificate no. FTZÚ 09 ATEX 0155X

Certificate was issued by Notified Body no. 1026, Physical Technical Testing Institute, Pikartska 7, 716 07 Ostrava Radvanice.

The following standards were applied: EN 60079-0:2009, EN 60079-11:2007,  
EN 50303:2000, EN 61241-11:2006, EN 60079-26:2007.

Temperature transmitters in Explosion-proof version are marked with the following certificate marking:


I M2 Ex d ia I Mb  
II 1/2G Ex ia/d IIC T\* Ga/Gb  
II 1/2D Ex ia/t IIIC T\* Da/Db

Certificate no. KDB 10ATEX222X

Certificates were issued by Notified Body no. 1453, Central Mining Institute, Plac Gwarków 1, 40-166 Katowice.

The following standards were applied: EN60079-0:2012, EN60079-1:2007,  
EN60079-11:2012, EN60079-26:2007, EN60079-31:2009.

Warsaw, 7th January 2014

Adam Żurawski  
  
General Manager